

Minimum specification for UPS Department of Animal Production and Health Technical Evaluation Report

UPS			
QTY			
S/ no	Item	Minimum Specification	Bidders Compliance
			Yes/ No If "No" indicate
If option available			
1	i. Make/Brand: (Should be mentioned by the bidder)		
2	ii. Model: (Should be mentioned by the bidder)		
3	iii. Country of origin: (Should be mentioned by the bidder)		
4	Input Power	180-270 Volts,50 Hz	
5	Output Power	230 Volts,50 Hz	
6	Output Slots	At least two output slots	
7	Backup Time	7-20 min or above	
8	Capacity	650 VA minimum	
9	Transfer Time	5ms or less	
10	Indicator	Audible power failure alarm,separate LED's for A/C power,battery charging,battery backup,low battery alarm(specify)	
11	Protection	Over voltage protection ,lighting protection,Short circuit protection,Surge protection	
12	Battery Type	Sealed & Maintaince free	
13	Recharge Time	6-8 hours to 90% Capacity	
14	Cables	One input power cable Two output Cables	
15	Warranty	Manufacture warranty for minimum one year,inclusive of replacement of all defective parts free of charge.All kind of repairs should be completed during the warranty period.	
17	Brochures	Brochures for the offered model(only) shall be submitted with the bid.	
18	Unit price without TAX(Rs)		
	Total Value (Rs.)		